



Fire Prevention Checklist

B CO 7-158th GSAB

Inspectors Name

Justin Gaughan

Date

07-07-2021

Is a unit Fire Prevention Representative appointed on orders?

YES

Are fire extinguishers available in all work areas, living areas, and HAZMAT storage areas?

YES

Are all fire extinguishers identified, tracked, and inspected monthly? Are annual 6 year and 12 year Hydrostatic tests properly tracked and documented?

YES

Are combustible and flammable materials stored properly?

YES

Are "NO SMOKING" signs posted in hangers, shops, and other work areas?

YES

Are "NO SMOKING" signs posted on Hazardous Materials storage containers?

YES

Are fire extinguisher points marked properly?

YES

Are fire points easily accessible (i.e. free of clutter)?

YES

Are fire evacuation plans posted in each work area?

YES

Are primary and alternate routes included on all fire evacuation plans?

YES

Are transformers placed on a non-combustible base and away from other combustible materials?

YES



Fire Prevention Checklist

B CO 7-158th GSAB

page 2

Are transformers plugged into wall outlets only?

YES

Are electrical appliances inspected periodically?

YES

Are appliances, such as coffee pots, turned off when not in use?

YES

Is there evidence of electrical overload?

NO

A minimum of one fire extinguisher per three aircraft on the flight line?

YES

Is the aircraft battery disconnected while parked in the hangar or on the flight line?

YES

Are all aircraft grounded while parked in the hangar or on the flight line?

YES

Are all soldiers trained on fire prevention techniques?

YES

Are soldiers trained in Fire Extinguisher use?

YES

Is the training documented and maintained on file?

YES

Do all soldiers understand what actions to take in the event of a fire? Is there a written SOP that covers Fire Prevention?

YES

Are oily rags kept in tightly covered metal containers? Evacuation route free of obstacles?

YES



Fire Prevention Checklist

B CO 7-158th GSAB

Page 3

Are exits and doors free of obstructions and unlocked during business hours?

YES

Are all exits marked with an illuminated "Exit" sign?

YES

Are smoke detectors installed in living and work areas and periodically tested?

YES

Have the 1st/2nd Semi-annual fire drills been conducted?

YES

Remarks